

INDIAN INSTITUTE OF TECHNOLOGY KANPUR**Tender Notice No. 52/Elect/2020****SCHEDULE OF QUANTITY****Name of Work: Supplying and fixing insulating mat in front of switch gear panel and DB at all blocks of Hall-12 & Hall-13.****Name of the Contractor**

S. No	Description of Items	Qty	Unit	Rate in Figures in Rupees	Amount
1	Supplying and laying / fixing with adhesive "shock safe" insulating mat in front of electrical panels, ISI marked (as per the latest standards of electrical mat ISI: 15652:2006) following Rubber or insulating mats should be provided in front of the main switchboards or any other control equipments of medium voltage and above as required complete.				
a	1.25 mtr width, 3.0 mm thick to withstand upto 3.3 KV dielectric strength, class A as per ISI: 15652:2006	550.00	Sq.mtr		
	Total Rs.				