

INDIAN INSTITUTE OF TECHNOLOGY KANPUR

DEPARTMENT OF CHEMISTRY

Tender No: IITK/CHM/DHD/15-16/001

Requirement: Exhaust system integration

Date: 13/04/2015

Quotations are requested from suppliers for the supply and installation of above item (for existing hood, ducting, starter and blower foundation) with following specifications.

- 1) Blower, 2000 CMH, 3 Phase, 1.5 HP, 2800 RPM, 50 mm back pressure suitability.
- 2) Suitable for the dimensions of Fume Hood, 5 feet × 2.5 feet, inside dimensions.
- 3) Blower casing fabricated in CRCA sheet, with CRCA forward curve fan, painted and balanced.

Please send the quotations with all the technical details by April 22, 2015 directly to the following address:

Dr. Dattatraya H. Dethe,
Lab- 101 D (Old Core Lab),
Department Of Chemistry,
Indian Institute of Technology
Kanpur.
Kanpur 208016, India.