



भारतीय प्रौद्योगिकी संस्थान कानपुर
INDIAN INSTITUTE OF TECHNOLOGY KANPUR
संगणक केन्द्र
COMPUTER CENTRE

पत्रालय-आई.आई.टी.कानपुर-208016(भारत)
P.O.-I.I.T. KANPUR - 208 016 (India)

CC/IITK/09/181
June 24, 2016

ADDENDUM

Reference: Tender no. CC/IITK/09/177 dated 16.6.2016

The dimension of the battery should be read as L-407 mm, W-173 mm, H-235 mm. However minor variation the dimensions will be permitted provided the length and width are not more than the mentioned values, otherwise the battery will not fit into the slots provided in the battery enclosure.

Certificate for UL and TS16949 compliance is not mandatory.

Last date for submission of technical & financial bid is extended 07.07.2016 at 1700 hrs.

Other terms and conditions remain the same.


(Dr. Y.N. Singh)
Head