

**Enquiry No: PI/CELT/2012-13/PKP/LTAS/02**

**Date: 15.06.2012**

**Specifications of 10KVA ONLINE UPS With 60min. Battery backup period (Revised)**

Capacity – 10 KVA  
Make of UPS – Uniline  
Waveform - Sine wave  
Battery – Exide (VAH – 16000)  
Standard Battery case/cover  
Warranty – 2 Years (on UPS & Batteries both)

**INPUT FEATURES**

Voltage(Vac) - 380/400/415  
Power Factor - 0.90(with optional filter)  
Phase – 3 Phase in 1 phase out  
Frequency(Hz) - 50

**OUTPUT FEATURES**

Voltage(Vac) - 220+ 1%, isolated output transformer  
Frequency(Hz) - 50 or 60 + 0.5% ( Battery mode)  
Power Factor - 0.8 std  
Overload Capacity - 12.5% load for 60s

**Service Center**

The company must have full-fledged registered service center at Kanpur with standby facility.

**Installation Base**

The Company must have proper installation base of 10KVA & above at Kanpur, Specially in IIT Kanpur .

Last Date for submitting quotations: 25th June 2012

Prof. P. K. Panigrahi  
Head, Laser Technology Program  
IIT Kanpur - 208016, UP, India