

INDIAN INSTITUTE OF TECHNOLOGY, KANPUR
INSTITUTE WORKS DEPARTMENT
DIVISION-III OFFICE

Letter No. IWD/Div-III/ **351**
Date: 27.08.2026

Corrigendum - I

Quotation No. IWD/Div-III/ 326

Dated 19/08/2026

Name of Work: - Bore Hole drilling and sub-soil Investigation for Construction of Faculty Apartment Block-E and F at IIT Kanpur

The queries submitted on the tender document for the subject work and clarifications from Institute side are as follows:

S.No.	Query	Clarification
1.	The phrase " in favour of the Director " appears to be incomplete/ambiguous	The earnest money (in the shape of FDR/DD) deposit is Rs. 12,013/- in favour of the Director, IIT Kanpur.
2.	In Price Bid Sl. No. 3.01 , it is mentioned that 4 boreholes of 30 m each are required.	"Tender Document Page No. 1, Sr. No. 2, it is mentioned that 8 boreholes, each of 40 m depth, are required." will supersede.
3.	- The basis/calculation for considering 50 Nos. of chemical analysis; - The number of soil samples to be collected/tested from each borehole; and - The specific chemical tests/parameters required for the samples.	- Out of the total samples that we take at different depth, 50 samples will be subjected to chemical tests. - Samples will be taken at specified intervals which may vary from 1.5m to 3m. - Sulphate content, chloride content, pH value etc.


Executive Engineer
(Civil Division-III)